

PROTECTOPLAS COMPANY

3500 Crane Center Dr.

Streetsboro OH 44241

(330) 562-8265

Fax: (330) 562-2560

WATER TEST PROCEDURE

STEP 1:

BLANK OFF ALL TANK FITTINGS.

STEP 2:

FILL TANK WITH CLEAN WATER TO TOP OF STRAIGHT SIDE. NO CHEMICALS ARE TO BE USED FOR TEST.

STEP 3:

ALLOW WATER TO SET FOR MINIMUM OF 6 HOURS.

STEP 4:

OBSERVE TANK FOR LEAKS.

STEP 5:

IF NO LEAKS, DRAIN TANK

IF LEAKS, REPAIR LEAKS AND REPEAT STEP 2

WATER TEST COMPLETED.