



| | | | NOZZLE SCHEDULE & ACCESSORY LIST | | |
|-----|-----|---------------------|----------------------------------|-----|------|
| | | | | | |
| TAG | QTY | TY SIZE DESCRIPTION | | DEG | ELEV |
| Α | 1 | 7 | THREADED TOP ACCESS | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | |
| | | | | | · |
| | | | | | |

GENERAL NOTES:

- 1. MATERIAL: TANK TO BE ONE PIECE MOLDED OF HIGH DENSITY POLYETHYLENE, COLOR: NATURAL, DESIGNED FOR CONTENTS TO 1.7 S.G. PER ASTM D1998-06 FOR TYPE II TANKS USING A 600 PSI HOOP
- 2. CONTENTS: WATER
- 3. OPERATING TEMP: 73° F
- 4. FLANGES TO BE HAND WELDED W/ NITROGEN GAS
- 5. ORIENT ALL FITTINGS FROM PLAN VIEW
- 6. TANK REQUIRES 100% BOTTOM SUPPORT
- 7. ALL PIPING & VALVES MUST HAVE IT'S OWN SUPPORT AND ALLOW FOR TANK EXPANSION & CONTRACTION OF 1.5% DIMENSIONAL MOVEMENT. FLEX CONNECTIONS SHOULD BE DESIGNED FOR A .5° ANGULAR MOVEMENT.
- 8. TANK IS TO BE LOCATED INDOORS
- 9. TANK IS DESIGNED FOR ATMOSPHERIC PRESSURE ONLY
- 10. ALL WFN/WPFN FLANGES ARE 150# BOLT SPACED PER ANSI B16.5, THEY ARE FULL RAISED FACE DESIGN AND REQUIRE FULL FACED GASKETS.
- 11. ALL WFN:WPFN NOZZLES REQUIRE 11 FT-LBS OF TORQUE TO SEAL. DO NOT OVER TIGHTEN FLANGES.
- 12. CHECK BOLT LENGTH WHEN PIPING TO A WPFN FLANGE BEFORE INSTALLATION. WPFN REQUIRE SHORTER BOLT LENGTHS.
- 13. CHECK ALL CHEMICAL AND TEMPERATURE COMPATIBILITY WITH CONSTRUCTION MATERIAL PRIOR TO TANK USE. PROTECTOPLAS DOES NOT WARRANT FOR CHEMICAL ATTACK OR PRODUCT MISUSE.
- 14. ALL DIM. ARE IN INCHES/DEGREES UNLESS OTHERWISE NOTED.
- 15. TOTAL VOLUME IS AN APPROX. FIGURE BASE ON BRIMFUL CAPACITY USING OUTER DIMENSIONS.

QUAN. REQ.: (1)

THIS DRAWING, THE NAME"PROTECTOPLAS", AND ALL LOGOS ARE PROPERTY OF EBCO INC. THEY MAYNOT BE ALTERED, COPIED, OR USED IN ANY WAY WITHOUT WRITTEN PERMISSION FROM EBCO INC.

| REV. NO. | REV. BY | REV. NOTE | | | |
|----------|------------------------------|-----------|--|--|--|
| CUSTOMER | | | | | |
| TITLE | TITLE VT100-28 VERTICAL TANK | | | | |



PROTECTOPLAS COMPANY

DIVISION OF EBCO, INC. STREETSBORO, OHIO 44241 USA

SCALE: NTS | BY: ZE | DATE: 10/9/2015 | DRW NO. VT100-28